

## **Manitoba Electrical Code Inspection Notice**

---

### **46-208 overcurrent protection**

#### ***Effective Date:***

Immediately

#### ***Scope:***

To clarify what needs to be installed on a parallel generator set installation.

#### ***Requirements:***

Rule 46-208 3)

The following is added after subrule 2) adding a new subrule 3)

- 3) For a parallel generator set each generator must terminate in:
  - i) a single overcurrent device: or
  - ii) a breaker at the paralleling switchgear

#### ***Rationale:***

There are no rules in the Canadian Electrical Code for parallel generator sets. This is what Manitoba Hydro will accept.

#### ***Supporting Information:***

Manitoba Electrical Code: Section 46

#### ***Issued By***

Manitoba Hydro  
Electrical Codes and Standards,